

NOTIFICATION OF ADDENDUM

ADDENDUM NO. 1

DATED 1/06/2014

Control	0179-03-029
Project	STP 2014(383)
Highway	SH 35
County	BRAZORIA

Ladies/Gentlemen:

Attached please find an addendum on the above captioned project. Included in the attachment is an addendum notification which details the changes and the respective proposal pages which were added and/or changed.

Except for new bid insert pages, it is unnecessary to return any of the pages attached.

Bid insert pages must be returned with the bid proposal submitted to the Department, unless your firm is submitting a bid using a computer print out. The computer print out must be changed to reflect the new bid item information.

Contractors and material suppliers, etc. who have previously been furnished informational proposals are not being furnished a copy of the addendum. If you have a subcontractor on the above project, please advise them of this addendum. Acknowledgment of this addendum is not requested if your company has been issued a proposal stamped "This Proposal Issued for Informational Purposes."

You are required to acknowledge receipt of this addendum on the Addendum Acknowledgement form contained in your bid proposal by placing a mark in the box next to the respective addendum.

Failure to Acknowledge receipt of this addendum in your bid proposal will result in your bid not being read.

SUBJECT: PLANS AND PROPOSAL ADDENDUMS

PROJECT: STP 2014(383)

CONTROL: 0179-03-029

COUNTY: BRAZORIA

LETTING: 01/08/2014

REFERENCE NO: 0103

PROPOSAL ADDENDUMS

- _ PROPOSAL COVER
- _ BID INSERTS (SH. NO.:
- X GENERAL NOTES (SH. NO.: N

- _ SPEC LIST (SH. NO.:
- _ SPECIAL PROVISIONS:
- ADDED:

DELETED:

- _ SPECIAL SPECIFICATIONS:
- ADDED:

DELETED:

X OTHER: PLAN SHEETS 14,16,17,28

DESCRIPTION OF ABOVE CHANGES
(INCLUDING PLANS SHEET CHANGES)

PLAN SHEETS 14,16,17 ADDED PAVEMENT EDGE DETAILS TO EACH SHEET
PLAN SHEET 28(SHEET N)ADDED PHRASE (, UNLESS OTHERWISE SHOWN IN PLANS.) TO
PARAGRAPH 6 UNDER ITEM 3268: AND DELETED (6H:1V) FROM PARAGRAPH 7.

General Notes:

General:

RAP generated by this project will become the property of the Contractor for use in the current construction project or in future projects.

If fixed features require, the governing slopes shown may vary between the limits shown and to the extent determined by the Engineer.

Superelevate the curves to match the existing surface.

References to manufacturer's trade name or catalog numbers are for the purpose of identification only. Similar materials from other manufacturers are permitted if they are of equal quality, comply with the specifications for this project, and are approved, except for roadway illumination, electrical, and traffic signal items.

The cost for materials, labor, and incidentals to provide for traffic across the roadway and for ingress and egress to private property in accordance with Section 7.7 of the standard specifications is subsidiary to the various bid items. Restore access roadways to their original condition upon completing construction.

Grade street intersections and median openings for surface drainage.

General: Roadway Illumination and Electrical

For roadway illumination and electrical items, use materials from pre-qualified producers as shown on the Construction Division (CST) of the Department's material producers list. Check the latest link on the TxDOT website for this list. The category/item is "Roadway Illumination and Electrical Supplies." No substitutions will be allowed for materials found on this list.

Perform electrical work in conformance with the National Electrical Code (NEC) and Department standard sheets.

General: Traffic Signals

For traffic signal items, use materials from pre-qualified producers as shown on the General Services Division (GSD) of the Department's material producers list. Check the latest links on the TxDOT website for this list, including (but not limited to): http://www.txdot.gov/txdot_library/consultants_contractors/publications/purchasing_specifications.htm under "Supplemental Specifications and Attachments." No substitutions will be allowed for materials found on this list.

General: Site Management

Mow the grass and weeds within the project limits a maximum of 3 times a year as directed. This work is subsidiary to the various bid items.

Mark stations every 100 ft. and maintain the markings for the project duration. Remove the station markings at the completion of the project. This work is subsidiary to the various bid items.

Do not mix or store materials, or store or repair equipment, on top of concrete pavement or bridge decks unless authorized by the Engineer. Permission will be granted to store materials on surfaces if no damage or discoloration will result.

Personal vehicles of employees are not permitted to park within the right of way, including sections closed to public traffic. Employees may park on the right of way at the Contractor’s office, equipment, and materials storage yard sites.

Assume ownership of debris and dispose of at an approved location. Do not dispose of debris on private property unless approved in writing by the District Engineer.

Control the dust caused by construction operations. For sweeping the base material in preparation for laying asphalt and for sweeping the finished concrete pavement, use one of the following types of sweepers or equal:

Tricycle Type
Wayne Series 900
Elgin White Wing
Elgin Pelican

Truck Type - 4 Wheel
M-B Cruiser II
Wayne Model 945
Mobile TE-3
Mobile TE-4
Murphy 4042

General: Traffic Control and Construction

Schedule work so that the base placement operations follow the subgrade work as closely as practical to reduce the hazard to the traveling public and to prevent undue delay caused by wet weather.

Item 5: Control of the Work

Submit shop drawings electronically for the fabrication of items as documented in Table 1 below. Information and requirements for electronic submittals can be viewed in the “Guide to Electronic Shop Drawing Submittal” which can be accessed through the following web link, ftp://ftp.dot.state.tx.us/pub/txdot-info/library/pubs/bus/bridge/e_submit_guide.pdf. References to 11 in. x 17 in. sheets in individual specifications for structural items imply electronic CAD sheets.

Table 1
2004 Construction Specification Required Shop/Working Drawing Submittals

Spec Item No.'s	Product	Submittal Required	Approval Required (Y/N)	Contractor/Fabricator P.E. Seal Required	Reviewing Party
7.8	Construction Load Analyses	Y	Y	Y	B
400	Excavation and Backfill for Structures (cofferdams)	Y	N	Y	A
403	Temporary Special Shoring	Y	N	Y	B
420	Formwork/Falsework	Y	N	Y	A
423	Retaining Walls, (calcs req'd.)	Y	Y	Y	C
425	Optional Design Calculations (Prstrs Bms)	Y	Y	Y	B
425	Prestr Concr Sheet Piling	Y	Y	N	B
425	Prestr Concr Beams	Y	Y	N	B
425	Prestr Concr Bent	Y	Y	N	B
426	Post Tension Details	Y	Y	N	B
434	Elastomeric Bearing Pads (All)	Y	Y	N	B
441	Bridge Protective Assembly	Y	Y	N	B
449	Sign-Structure Anchor Bolts	Y	Y	N	T
450	Railing	Y	Y	N	A
462	Concrete Box Culvert	Y	Y	N	C
462	Concrete Box Culvert (Alternate Designs Only, calcs reqd.)	Y	Y	Y	B
464	Reinforced Concrete Pipe (Jack and Bore only; ONLY when requested)	Y	Y	Y	A
465	Pre-cast Junction Boxes, Grates, and Inlets	Y	Y	N	A
465	Pre-cast Junction Boxes, Grates, and Inlets (Alternate Designs Only, calcs req'd.)	Y	Y	Y	B
466	Pre-cast Headwalls and Wingwalls	Y	Y	N	A
467	Pre-cast Safety End Treatments	Y	Y	N	A
495	Raising Existing Structure (calcs reqd.)	Y	Y	Y	B
610	Roadway Illumination Supports (Non-Standard only, calcs reqd.)	Y	Y	Y	T
613	High Mast Illumination Poles (Non-standard only, calcs reqd.)	Y	Y	Y	T
627	Treated Timber Poles	Y	Y	N	T
644	Special Non-Standard Supports (Bridge Mounts, Barrier Mounts, Etc.)	Y	Y	Y	T
647	Large Roadside Sign Supports	Y	Y	Y	T
650	Cantilever Sign Structure Supports - Alternate Design Cacls.	Y	Y	Y	T
650	Sign Structures	Y	Y	N	T
652	Highway Sign Lighting Fixtures	Y	Y	N	T
654	Sign Walkways	Y	Y	N	T
680	Installation of Highway Traffic Signals	Y	Y	N	T
682	Vehicle and Pedestrian Signal Heads	Y	Y	N	T
684	Traffic Signal Cables	Y	Y	N	T
685	Roadside Flashing Beacon Assemblies	Y	Y	N	T
686	Traffic Signal Pole Assemblies (Steel) (Non-Standard only)	Y	Y	Y	T
687	Pedestal Pole Assemblies	Y	Y	N	T
688	Detectors	Y	Y	N	A
784	Repairing Steel Bridge Members	Y	Y	Y	B
SS	Prestr Concr Crown Span	Y	Y	N	B
SS	Sound Barrier Walls	Y	Y	N	B
SS	Camera Poles	Y	Y	Y	TMS

SS	Pedestrian Bridge (Calcs req'd.)	Y	Y	Y	B
SS	Screw-In Type Anchor Foundations	Y	Y	N	T
SS	Fiber Optic/Communication Cable	Y	Y	N	TMS
SS	Spread Spectrum Radios for Signals	Y	Y	N	T
SS	VIVDS System for Signals	Y	Y	N	T
SS	CTMS Equipment	Y	Y	N	TMS

Key to Reviewing Party

A - Area Office	
Area Office	Email Address
Brazoria Area Office	HOU-BRZAShpDrwgs@txdot.gov
Traffic Systems Construction Office	HOU-TSCShpDrwgs@txdot.gov
C - Construction Office	
Construction	HOU-ConstrShpDrwgs@txdot.gov
Laboratory	HOU-LabShpDrwgs@txdot.gov

T - Traffic Engineer	
Traffic Operations	HOU-TrfShpDrwgs@txdot.gov
TMS – Traffic Management System	
Computerized Traffic Management Systems (CTMS)	HOU-CTMSShpDrwgs@txdot.gov

Item 7: Legal Relations and Responsibilities

Do not initiate activities in a Project Specific Location (PSL), associated with a U.S. Army Corps of Engineers (USACE) permit area, that have not been previously evaluated by the USACE as part of the permit review of this project. Such activities include those pertaining to, but are not limited to, haul roads, equipment staging areas, borrow and disposal sites. Associated defined here means materials are delivered to or from the PSL. The permit area includes the waters of the U.S. or associated wetlands affected by activities associated with this project. Special restrictions may be required for such work. Assume responsibility for consultations with the USACE regarding activities, including PSLs that have not been previously evaluated by the USACE. Provide the Department with a copy of consultations or approvals from the USACE before initiating activities.

The Contractor may proceed with activities in PSLs that do not affect a USACE permit area if a self-determination has been made that the PSL is non-jurisdictional or if proper USACE clearances have been obtained in jurisdictional areas or have been previously evaluated by the USACE as part of the permit review of this project. The Contractor is solely responsible for documenting any determinations that their activities do not affect a USACE permit area. Maintain copies of their determinations for review by the Department or any regulatory agency.

Document and coordinate with the USACE, if required, before hauling any excavation from or hauling any embankment to a USACE permit area by either 1 or 2 below:

1. Restricted Use of Materials for the Previously Evaluated Permit Areas.

Document both the Project Specific Locations (PSL) and their authorization. Maintain copies for review by the Department or any regulatory agency. When an area within the project limits has been evaluated by the USACE as part of the permit process for this project:

- a. Suitable excavation of required material in the areas shown on the plans and cross sections as specified in the Item, "Excavation" is used for permanent or temporary fill (under the Item, "Embankment") within a USACE permit area.
- b. Suitable embankment (under the Item, "Embankment") from within the USACE permit area is used as fill within a USACE evaluated area.
- c. Unsuitable excavation or excess excavation, "Waste" (under the Item, "Excavation"), that is disposed of at a location approved within a USACE evaluated area.

2. Contractor Materials from Areas Other than Previously Evaluated Areas.

Provide the Department with a copy of USACE coordination or approvals before initiating any activities for an area within the project limits that has not been evaluated by the USACE or for any off right of way locations used for the following, but not limited to, haul roads, equipment staging areas, borrow and disposal sites:

- a. The Item, "Embankment" used for temporary or permanent fill within a USACE permit area.
- b. Unsuitable excavation or excess excavation, "Waste" (under the Item, "Excavation"), that is disposed of outside a USACE evaluated area.

This project does not require a U.S. Army Corps of Engineers (USACE) Section 404 Permit before letting, but if a permit is needed during construction, assume responsibility for preparing the permit application. Submit the permit application to the Department's District Environmental Section for approval. Once the permit application is approved, the Department will submit it to the USACE. Assume responsibility for the requested revisions, in coordination with the Department's District Environmental Section.

Do not store any material in Waters of the United States inside the right of way without written approval.

Before construction operations begin, provide a drawing of the location of proposed temporary access roads, haul roads, or temporary fill used during construction operations to ensure that they are not within Jurisdictional Waters of the United States.

If the Contractor elects to use an area not permitted and determined to be within Jurisdictional Waters of the United States during the prosecution of the work, the Contractor will hold the Department harmless for delays caused by procuring the necessary permits from the United States Army Corps of Engineers.

Maintain the roadway slope stability. Maintaining slope stability is subsidiary to the various bid items.

Item 8: Prosecution and Progress

The Department will supply bidders, upon written request, one electronic copy of the time determination schedule. The time determination schedule provided is for informational use only and is not intended for bidding or construction purposes.

The Department will not adjust the number of days for the project and milestones, if any, due to differences in opinion regarding any assumptions made in the preparation of the schedule or for errors, omissions, or discrepancies found in the time determination schedule.

Working days will be computed and charged based on a Standard workweek in accordance with Section 8.3.A.4.

Item 134: Backfilling Pavement Edges

Quantity by station includes both sides of the roadway.

The Contractor has the option of selecting the type of backfill material consisting of Reclaimable Asphalt Pavement (RAP), Flex Base, or Crushed Concrete provided that it meets the requirements listed below.

If using salvaged asphalt concrete pavement, size it so that all the material, passes the 2-in. sieve. Use RAP that does not contain deleterious material such as clay or organic material.

Flex Base must meet the requirements of Item 247, Type A, Grade 1. Department Test Method Tex-117-E will not be required.

Crushed concrete must meet the requirements of Item 247, Grade 1. Department Test Methods Tex-116-E and Tex-117-E will not be required.

Place emulsified asphalt (SS-1, CSS-1, or CSS-1H) at an application rate of 0.25 gal/sq. yard.

Item 204: Sprinkling

Perform subsidiary sprinkling as required under various other items in accordance with the Item, "Sprinkling."

Sprinkling for dust control is subsidiary to the various bid items.

Item 275: Cement Treatment (Road-Mixed)

Use a commercial testing laboratory approved by the Brazoria Area Engineer's Office to perform the 7-day unconfined Compressive Strength testing as shown in Table 1. Submit to the Department certified test reports 15 days prior to beginning base construction. A minimum of three test will be required for the project and up to two additional tests may be required if

differing materials are encountered. Locations will be determined by the engineer. Provide all testing at no cost to the Department.

Based on the above mentioned certified laboratory test reports, the Engineer will designate a target cement content and optimum moisture content necessary to produce a stabilized mixture that meets the minimum and maximum cement percentage and exceed the strength requirements shown below in Table 1.

Table 1
Requirements for Cement Treatment

Description	Minimum	Maximum
Cement	4 ½ percent	6 percent
	Test Method	Minimum
7-Day Unconfined compressive Strength ¹	Tex-120-E, Part I	300 psi

1. Meet the minimum unconfined compressive strength after addition of stabilizer.

Cure the final course of cement treatment using an asphalt distributor that distributes the approved curing material at a rate of 0.25 gallons per square-yard evenly and smoothly or as recommended by the manufacturer at the recommended dilution rate, under a pressure necessary for proper distribution. If at any time prior to placing final course it is determined that the curing material already applied does not meet the requirements of the item “Asphalts, oils, and Emulsions” another layer of curing material will be applied at Contractors expense. Provide a curing material meeting the requirements of the Item, “Asphalts, Oils, and Emulsions” for curing the cement treatment. Use the following materials for curing the courses of cement treatment:

Curing Material

Water
PCE

Application

All courses, except final course
Final course

Curing material is incidental to this bid item.

Do not place cement before 9:00am or after 3:00pm.

Item 292: Asphalt Treatment (Plant-Mixed)

If using the iron ore topsoil as the primary aggregate, meaning 80 percent or more by weight of the total mixture, the requirements for the water susceptibility test are waived.

Mixtures containing the iron ore topsoil are exempted from test methods TEX-217-F (Part I, separation of deleterious material and Part II, decantation test for coarse aggregate) and TEX-203-F (Sand Equivalent Test).

Assume responsibility for proportioning the materials entering the asphalt mixture, regardless of the type of plant used.

Furnish the mix designs for approval.

Compact the courses to a minimum density of 95 percent of the maximum density as determined using test method TEX-126-E.

Item 305: Salvaging, Hauling, and Stockpiling Reclaimable Asphalt Pavement

Unless otherwise shown on the plans, RAP generated by this project will become the property of the Contractor for use in the current construction project or in future projects.

Verify the depth of asphalt pavement to be removed before beginning the removal.

Taper transverse faces to provide acceptable ride.

Item 318: Hot Asphalt-Rubber Surface Treatments

Placing surface treatments is limited to the period of May 1 to September 15, inclusive, unless written approval is obtained to extend the placement period if weather conditions warrant an extension.

The asphalt application rate shown on the “Basis of Estimate” is an average rate for calculating asphalt quantities. Vary the rate based on the pavement conditions and other factors such as the type and grade of aggregate used, weather, and traffic.

Item 351: Flexible Pavement Structure Repair

Use asphalt stabilized base for the base material.

For base repair, place the asphalt stabilized base in compacted lifts of 4 in. maximum, unless otherwise directed.

Item 502: Barricades, Signs, and Traffic Handling

Use a traffic control plan for handling traffic through the various phases of construction. Follow the phasing sequence unless otherwise agreed upon by the Area Engineer and the Project Manager. Ensure this plan conforms to the latest “Texas Manual on Uniform Traffic Control Devices” and the latest Barricade and Construction (BC) Standard Sheets.

Submit changes to the traffic control plan to the Area Engineer. Provide a layout showing the construction phasing, signs, striping, and signalizations for changes to the original traffic control plan.

Furnish and maintain the barricades and warning signs, including the necessary temporary and portable traffic control devices, during the various phases of construction. Place and construct these barricades and warning signs in accordance with the latest “Texas Manual on Uniform Traffic Control Devices” for typical construction layouts.

Cover work zone signs when work related to the signs is not in progress, or when any hazard related to the signs no longer exists.

Keep the delineation devices, signs, and pavement markings clean. This work is subsidiary to the Item, "Barricades, Signs, and Traffic Handling."

If a section is not complete before the end of the workday, pull back the base material to the existing pavement edge on a 6H: 1V slope. Edge drop-offs during the hours of darkness are not permitted.

Before detouring traffic onto the mainlane shoulders, remove dirt, debris, vegetation, and other deleterious material from the surface of the shoulders. Appropriately sign the detour in an approved manner. This work is subsidiary to the various bid items.

Cover or remove the permanent signs and construction signs that are incorrect or that do not apply to the current situation for a particular phase.

Do not mount signs on drums or barricades, except those listed in the latest Barricades and Construction standard sheets.

Use traffic cones for daytime work only. Replace the cones with plastic drums during nighttime hours.

Place positive barriers to protect drop-off conditions greater than 2 ft. within the clear zone that remain overnight.

Use shadow vehicles with Truck Mounted Attenuators (TMA) for lane and shoulder closures.

Do not reduce the existing number of lanes open to traffic except as shown on the following time schedule:

One Lane Closure

Day	Daytime Closure Hours	Nighttime Closure Hours	Restricted Hours Subject to Lane Assessment Fee
Monday - Friday	No Restrictions Except as Noted Below	As Approved by Engineer	None
Saturday	As Approved by Engineer	As Approved by Engineer	None
Sunday	As Approved by Engineer	As Approved by Engineer	None

*Do not place cement before 9:00 am or after 3:00 pm.

The above times are approved for the traffic control conditions listed. The Area Engineer may approve other closure times if traffic counts warrant. The Area Engineer may reduce the above times for special events.

Law enforcement assistance will be required for this project and is expected to be required for major traffic control changes and lane closures. Coordinate with local law enforcement and arrange for law enforcement as directed or agreed by the Engineer. Before payment will be made, complete the "Daily Report on Law Enforcement Force Account Work" (Form 318),

provided by the Department and submit daily invoices that agree with this form for any day during the month in which approved services were provided.

Provide full-time, off-duty, uniformed, certified peace officers, as part of traffic control operations. The peace officers must be able to show proof of certification by the Texas Commission on Law Enforcement Officers Standards. The cost of the officers is paid for on a force account basis.

Use Uneven Lane Signs (CW 8-11) during resurfacing operations for elevation differences between adjacent lanes of greater than 1 in.

The Contractor Force Account "Safety Contingency" that has been established for this project is intended to be utilized for work zone enhancements, to improve the effectiveness of the Traffic Control Plan, that could not be foreseen in the project planning and design stage. These enhancements will be mutually agreed upon by the Engineer and the Contractor's Responsible Person based on weekly or more frequent traffic management reviews on the project. The Engineer may choose to use existing bid items if it does not slow the implementation of enhancement.

Item 585: Ride Quality for Pavement Surfaces

To eliminate the need for corrective action due to excessive deviations in the final surface layers, exercise caution to ensure satisfactory profile results in the intermediate paving layers (mixture).

Milling will not be allowed as a corrective action for excessive deviations in the final surface layer of hot-mix asphalt.

For asphalt mainlanes and direct connectors, use Surface Test Type B and Pay Adjustment Schedule 3.

For all other roads (cross streets and intersections), use Surface Test Type A.

Item 618: Conduit

Item 620: Electrical Conductors

Item 628: Electrical Services

If the specifications for electrical items require UL-listed products, this means UL-listed or CSA-listed.

Item 618: Conduit

When backfilling bore pits, ensure that the conduit is not damaged during installation or due to settling backfill material. Compact select backfill in 3 equal lifts to the bottom of the conduit; or if using sand, place it 2 in. above the conduit. Ensure backfill density is equal to that of the existing soil. Prevent material from entering the conduit.

Construct bore pits a minimum of 5 ft. from the edge of the base or pavement. Close the bore pit holes overnight.

Unless shown on the plans, install underground conduit a minimum of 24 in. deep. Install the conduit in accordance with the latest National Electrical Code (NEC) and applicable Department standard sheets. Place conduit under driveways or roadways a minimum of 24 in. below the pavement surface.

If using casing to place bored conduit, the casing is subsidiary to the conduit.

Remove conductor and conduit to be abandoned to 1 ft. below the ground level. This work is subsidiary to the various bid items.

Use only a flat, high tensile strength polyester fiber pull tape to pull conductors through the PVC conduit system.

Use materials from pre-qualified producers as shown on the Department's Construction Division (CST) material producers list. Check the latest links on the TxDOT website for the list. The category is "Roadway Illumination and Electrical Supplies." The polymer concrete barrier box is subsidiary to Item 618, "Conduit."

Item 620: Electrical Conductors

Test each wire of each cable or conductor after installation. Incomplete circuits or damage to the wire or the cable are cause for immediate rejection of the entire cable being tested. Remove and replace the entire cable at no expense to the Department. Also test the replacement cable after installation.

When pulling cables or conductors through the conduit, do not exceed the manufacturer's recommended pulling tensions. Lubricate the cables or conductors with a lubricant recommended by the cable manufacturer.

Ensure that circuits test clear of faults, grounds, and open circuits.

Split bolt connectors are allowed only for splices on the grounding conductors.

For electrical licensing and electrical certification requirements for this project, see Item 7 of the Standard Specifications and any applicable special provisions to Item 7.

Item 624: Ground Boxes

The ground box locations are approximate. Alternate ground box locations may be used as directed, to avoid placing in sidewalks or driveways.

During construction and until project completion, provide personnel and equipment necessary to remove ground box lids for inspection. Provide this assistance within 24 hours of notification.

Construct concrete aprons in accordance with the latest standard sheet ED (3). Make the depth of the concrete apron the same as the depth of the ground box, except for Type 1 and Type 2 ground boxes. For Type 1 or Type 2 ground boxes, construct the concrete apron in accordance with details shown on the "Ground Box Details Installations" standard.

Item 662: Work Zone Pavement Markings

At the end of each day's work, mark roadways that remain open to traffic during construction operations with standard pavement markings, in accordance with the latest "Texas Manual on Uniform Traffic Control Devices."

Do not use raised pavement markers as optional work zone pavement markings on final asphalt surfaces.

For transition lane lines and detour lane lines, use raised pavement markers as shown for solid lines on the latest Barricade and Construction standard sheet for "Work Zone Pavement Marking Details."

Item 662: Work Zone Pavement Markings

Item 666: Reflectorized Pavement Markings

Use Type III glass beads for thermoplastic pavement markings.

Use a 0.100 in. (100 mil) thickness for thermoplastic pavement markings, measured to the top of the thermoplastic, not including the exposed glass beads.

For roadways with asphalt surfaces to be striped with work zone or permanent thermoplastic markings, the Contractor has the option to apply paint and beads markings for a maximum 30-day period until placing the thermoplastic markings, or until starting the succeeding phase of work on the striped area. Maintain the paint and beads markings, at no expense to the Department, until placing the thermoplastic markings or starting the succeeding phase of work on the striped area. The work zone markings, whether paint and beads or thermoplastic, are paid under the Item, "Work Zone Pavement Markings" and the markings are paid for only once for the given phase of construction.

If using paint and bead markings as described above, purchase the traffic paint from the open market.

If the Type II markings become dirty and require cleaning by washing, brushing, compressed air, or other approved methods before applying the Type I thermoplastic markings, this additional cleaning is subsidiary to the Item, "Reflectorized Pavement Markings."

Establish the alignment and layout for work zone striping and permanent striping.

Stripe roadways before opening them to traffic.

Place pavement markings under these items in accordance with details shown on the plans, the latest "Texas Manual on Uniform Traffic Control Devices," or as directed.

When design details are not shown on the plans, provide pavement markings for arrows, words, and symbols conforming to the latest "Standard Highway Sign Designs for Texas" manual.

Item 672: Raised Pavement Markers

If other operations are complete on the project and if the curing time period is not yet elapsed, the contract time will be suspended until the curing is done.

Before placing the raised pavement markers on concrete pavement, blast clean the surface using an abrasive-blasting medium. This work is subsidiary to the Item, "Raised Pavement Markers."

Provide epoxy adhesive that is machine-mixed or nozzle-mixed and dispensed. Equip the machine or nozzle with a mechanism to ensure positive mix measurement control.

Item 688: Pedestrian Detectors and Vehicle Loop Detectors

Install a rubber grommet or bushing between the push button assembly and the signal pole to protect the conductors.

Provide a black tube loop detector wire as specified in the "International Municipal Signal Association, Inc." (IMSA) Specification No. 51-7, 1997.

If the loop sealant supplied by the Contractor is not on the Department's pre-qualified product list, before applying the sealant provide a 5-gal. container of loop sealant for testing.

Item 1122: Temporary Erosion, Sedimentation and Environmental Controls

The use of hay bales is not permitted as Storm Water Pollution Prevention Plan (SW3P) measures.

The Storm Water Pollution Prevention Plan (SW3P) consists of temporary erosion control measures needed and provided for under this Item. The disturbed area is less than one acre and use of erosion control measures is not anticipated. If physical conditions encountered at the job site require necessary controls, BMP installation, maintenance, and removal will be paid as extra work on a force account basis per Articles 4.2 and 9.5. Since the disturbed area is less than 5 acres, a "Notice of Intent" (NOI) is not required.

Use appropriate measures to prevent, minimize, and control the spill of hazardous materials in the construction staging area. Remove and dispose of materials in compliance with State and Federal laws.

Implement temporary and permanent erosion control measures to comply with the National Pollution Discharge Elimination System (NPDES) general permit under the Clean Water Act.

Before starting grading operations and during the project duration, place the temporary or permanent erosion control measures to prevent sediment from leaving the right of way.

Item 3268: Dense-Graded Hot Mix Asphalt

Begin ACP Overlay within 10 calendar days of placing surface treatment.

Tie HMAACP tapers to a vertical transition joint created by the milling operation at the beginning and ending transitions and at all exceptions, or as directed. Provide a temporary HMAACP taper at vertical joints until overlay operations begin.

Place the inside shoulder with the inside main lane continuously through median crossovers on 4-lane divided highways.

Limit uneven pavement to two days production with the requirement that all longitudinal joints adjacent to a travel way are constructed with a joint maker providing a maximum of one inch vertical edge (1/2" desirable) with adjacent 6:1 taper.

Taper the asphalt concrete pavement at the beginning and ending points.

Use a maximum 6H:1V slope for the asphalt concrete pavement edge, unless otherwise shown in plans.

Where the ACP edge taper extends over onto the unsurfaced shoulders, blade off the loose existing shoulder material to provide a solid base for the outside taper edge. After placing the ACP overlay, blade this material back against the edge taper. This work is subsidiary to the various bid items.

The stockpile will be the point of sampling of coarse aggregate for test method TEX-217-F (Part II, decantation).

Place the asphalt concrete pavement in courses as shown on the typical sections.

Do not use petroleum-based solvents in the beds of hot mix asphalt delivery vehicles.

Dilution of tack coat is not allowed.

Do not use Surface Aggregate Classification (SAC) C for this project.

For determining the Asphalt Content, only ignition ovens will be allowed.

Basis of Estimate

Item	Description	Limit and Rate	Unit
275	Cement Treatment (Road-Mixed) For materials used as subgrade <ul style="list-style-type: none"> • Cement 	4.5 % by weight based on 138 Lb. / Cu. Ft.	SY TON
292	Asphalt Treatment (Plant-Mixed) <ul style="list-style-type: none"> • Asphalt • Aggregate 	110 Lb. / Sq. Yd.-In. 5 % by weight 95 % by weight	TON
318	Surface Treatments (A-R Binder) <ul style="list-style-type: none"> • Asphalt (Rubber) • Aggregate 	0.55 Gal/ Sq. Yd. 1/100 Cu. Yd. / Sq. Yd.	GAL CY
3268	Dense-Graded Hot Mix Asphalt <ul style="list-style-type: none"> • Asphalt • Aggregate 	110 Lb. / Sq. Yd.-In. 6 % by weight 94 % by weight	TON

This page intentionally left blank.