

PRE-LETTING QUESTIONS AND ANSWERS

CONTROL: 0632-04-034
 PROJECT: STP 2019(262)
 HIGHWAY: FM 9

COUNTY: Harrison
 LET DATE: December 2018

AREA OFFICE: Marshall
 AREA ENGINEER: Ray Brady

DOCUMENT LAST UPDATED ON: 4/12/2018 5:10 PM

#	DATE	QUESTION	ANSWER
1	12/4/2018	On sheet 3 of the plans, what does CZ stand for	CZ stands for clear zone
2	12/4/2018	Are the mixture design properties and maximum dry density shown in the General Notes to Item 3063 good for the entire project length?	Yes. The expectation would be to use these for the entire project length.
3	12/4/2018	On sheet 4 of the plans there are vertical and horizontal curve data given. Are these to be used in the roadway construction.	No. A note on the sheet says that these are not intended for use in construction.
4	12/4/2018	In the General Notes to Item 3063 it states to place cement in an essentially dust free manner. What does that mean.	The expectation would be to use some form of shroud or cover at the spreader bar such that cement dust is contained and not allowed to form large clouds that impede traffic flow and settle on nearby property.
5	12/4/2018	Will alternate construction phasing be allowed from that shown on sheet 24 Traffic Control Plan (Foamed Asphalt Treat)?	The expectation is to follow the sequence as prescribed on this sheet.
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			