

CSJ 0099-01-035

1. Question: Can TY II paint be used for item 662 work zone non-remove items?

Answer: Paint or thermoplastic will be allowed for work zone non-removeable markings.

Received: 12/23/2021

Answered: 12/28/2021