

CSJ: 0923-06-077 Q & A

Question: 1) I am looking at this project calling out 1 Sacrificial CCA's but there is not a summary sheet or standards attached. Can you please let me know if we can use the Absorb M for this project?

Answer: 1) On sheet number 29, the plan view calls for a BEAT SSCC-16 to be used at this location. The standard was not incorporated into the plans but the pay item is correct on the E&Q sheet. Please bid the job with the Crash Cushion shown on the estimate and quantity sheet.

Received: 09/16/2020

Responded: 09/25/2020