

Pre-Bid Q & A CSJ 1028-01-030 FM 574 Mills County

1. On the above referenced project that bids in September, the bid item 0545 6007 is for a low maintenance crash cushion but the CCSS show sacrificial units are required and the standard sheets are all sacrificial. Can you please clarify?
See addendum.
2. What is the pavement section for the driveway?
Proposed pavement section is 8" of Type B hot mix (3076).
3. What is the pavement section for the CONSTRUCT DETOUR item? I don't see it in the plans.
See addendum.
4. What is the pavement section for the DRIVEWAYS (ACP)?
See addendum.
5. Requesting the full geotechnical report with narrative for Mills Co. 1028-01-030.
See addendum.
6. Will this project require a field office besides the HMAC Lab?
No field office trailer will be required.
7. Can Type F CTB be substituted for Single Slope?
Type F CTB will not be allowed to substitute for single slope CTB.
8. We will be allowed to put in a temporary crossing?
A temporary crossing in the ROW will not be allowed due to limited ROW width.