

**October 31, 2019**

**Q:** Can a time determination schedule be provided for this project?

**A:** We will have the time determination posted to the FTP site ASAP for your information.

**Q:** Will existing power poles that may interfere with curb ramp and sidewalk construction be relocated?

**A:** I am visiting with our advanced planning department to find out the extent of relocation that has/has not taken place yet. I will update via FTP site with further clarification.

*(November 4, 2019 - utility poles that are in conflict of providing a TDLR minimum clearance of 3' walking path have been relocated, however there are still some utility poles that may or may not be relocated prior to construction. If the poles or pole foundations end up remaining in place, sidewalk, colored stamped buffer, or portions of ramps may need to be cast around the poles).*

**Q:** Is removing the Type I curb subsidiary to placing new curb at the locations specified?

**A:** I acknowledge that there is a discrepancy here and that no bid item or clarification is in the plans for removing the TY I curb. I will follow up via the FTP site with clarification on this one as well. *(November 4, 2019 - please bid the item as shown acknowledging that circumstances may require additional removal of TY I curb to construct new curbs).*