

DATE RECEIVED	QUESTION	TxDOT RESPONSE
4/29/2019	Plan sheet 7 shows a table of quantities for the project. From station 245+75 – 264+00, the table doesn't show a one-course underseal or TY D HMA, just TBWC, but the proposed typical sections on plan sheet 4 seem to show that all areas of the project have underseal and TY D. Can you please confirm that these stations only receive TBWC? ☐	The typicals for Sta 245+75 to Sta 264+00 shown of sheet 4 are incorrect. The Roadway Quantities shown on sheet 7 are correct.
5/7/2019	Is night work required?	Bid as shown in the plans. See note on sheet 18: "The Contractor may submit an alternate signed and sealed traffic control plan and/or an alternate sequence of construction in advance and in writing. Subject to approval of the Engineer."