

Date Received	Date Updated	Question	TXDOT Response
4/24/2019	4/25/2019	<i>For bid item 467-6173 SET (TY I) (S=5 FT) (HW=3 FT) (6:1) (C), the culvert layouts call for standard SETB-SW-O to be used but the BCS sheet calls for the SETB-CD standard to be used. Which standard should we follow for these end treatments? If we are to use the SETB-SW-O standard, page 3 of 3 does not contain any specs in the plans.</i>	The proposed SET's at STA 135+62 (Sheet 95) and STA 285+56 (Sheet 96) are called out as SETB-FW-0 and SETB-SW-0. These should be labeled as SETB-CD instead, and the contractor should follow the SETB-CD standard as called out in the BCS sheet