

# Transportation Operations

# Questions

# Response

Date	Date Updated	Questions	TXDOT Response
2/13/2020		Are formal project barricades going to be required on this project? If yes, are they only needed at the two ends of SH 286 and not on any of the cross streets?	Yes, and only at each end.
2/17/2020		Bid item 6000-6009 replace conductors is the existing conductors No 8. No 6 that run from pole to pole and then to electrical services. There are no items if conduits are damage or prepare conduit to pull in new cables, are there any issues with the existing electrical services that we need to be aware of?	If there are any issues with the electrical services TxDOT forces will handle. As per item 6000 in the general notes: "Use conductor size 12AWG stranded for Item 600-6009." This conductors is for conductor going up the pole to the luminaire head.
2/18/2020		In the plans under general notes Item 8 Prosecution and Progress the fifth paragraph states that the contractor shall complete the work within the time allotted. Work may begin when materials become available from the department. Is TXDOT providing the material for this contract?	TxDOT will not be providing materials.