



CSJ: 0918-46-330
Highway: Various
County: Denton

QUESTIONS/REQUEST	ANSWERS
7/19/2022	
Will a mechanical method be permitted for the removal of the 12" & 24" crosswalks and stop bars? (Item 677)	Item 677, Section 4, in the 2014 TxDOT Standard Specifications allows for a mechanical method for removing paving markings. As long as the mechanical method satisfies the criteria in Item 677.4 Construction, it would be acceptable.