	FM 544, CSJ: 0619-03-061		
	CSJ:		0619-03-061
	LIMITS FROM:		At FM1378
	LIMITS TO:		
	DATE	QUESTION	ANSWER
1	4/12/2022	We are preparing our bid for the referenced project and request that you populate the FTP with any and all cross sections, pavement design reports, earthwork files, digital earthwork data (*.XSR format, if possible), geotechnical reports, global stability analysis, time calculation data, subsurface utility plans, detour cross sections, ROW Maps, and other files/data you may have available to assist in our preparation of a proposal for this project at your earliest convenience..	We are placing availble information in th sub directory named "Documents 4122022". We don't have .xsr file as we are just widening pavement using existing slope.
2	4/28/2022	Is a Pre Bid Meeting being held? No, a pre-bid meeting is not being held?	No, a pre-bid meeting is not being held
3	4/28/2022	Are bids accepted in person or online?	Both. For questions regarding how to submit a bid, please contact the Construction Division.
4	5/2/2022	Please confirm that the subcontractors DBE commitment information will NOT provided with the bid day submission but within 5 calendar days per Article 2.14 on the Special Provision to Item 2 Instructions to Bidders.	This is correct. DBE's are to be provided within 5 calendar days per Article 2.14.
5	5/2/2022	On Special Provision to Item 000 Notice of Requirement for Affirmative Action to Ensure Equal Employment Opportunity is listed Goals for female participation in each trade equal 6.9%. Please clarify if it's applicable to be committed in this project?	Female participation is not specifically tracked, as the DBE goal is. However, because this is a federal requirement, the prime contractor must add SP 000-004 to their agreements with subcontractors
6	5/2/2022	How do I add the subcontractors in the ICX website to meet the DBE goal?	Please contact the Office of Civil Rights for a walk through of this procedure at 512-416-4700
7	5/3/2022	We located 14 different Special Specifications (SS) (612 pages) for bid items that cover the construction of the water line and its appurtenances. Most of them cover material presented in other SS items. Can those not be merged/combined to get that work covered under fewer SS requirements? So many SS requirements will make construction in the field quite the challenge, for both parties.	15 SS items are deleted with Addendum 1.
8	5/3/2022	We located Special Specification 7016 in the proposal. The only item that refers to SS7016 is 7016 6093 CASING (STEEL)(30 N)(BORED). Please confirm the other requirements of this specification DO NOT apply to other bid items, except as directly referenced.	SS 7016 is deleted with Addendum 1.
9	5/3/2022	We located Special Specification 7021 in the proposal. The only item that refers to SS7021 is 7021 6041 GRAVEL. Please confirm the other requirements of this specification DO NOT apply to other bid items, except as directly referenced.	SS 7021 is deleted with Addendum 1.
10	5/3/2022	Special Specification 7021 contains a prequalification requirement for the performance of this work by a contractor prequalified by the City of Fort Worth Water Department. Please confirm this prequalification requirement, and any other City of Fort Worth references, DO NOT apply to this project.	SS 7021 is deleted with Addendum 1.
11	5/3/2022	Special Specification 7152 contains a requirement to contact Ken Cross with the City of North Richland Hills prior to construction. Please confirm this requirement, and any other North Richland Hills references, DO NOT apply to this project.	SS 7152 is deleted with Addendum 1.
12	5/3/2022	Special Specification 7169 contains a requirement to obtain permits from the City of Grand Prairie. Please confirm this requirement, and any other Grand Prairies references, DO NOT apply to this project.	SS 7169 is deleted with Addendum 1.
13	5/3/2022	Special Specification 7170 contains a requirement to perform construction as required by the City of Lucas. Please confirm this requirement, and any other Lucas references, DO NOT apply to this project.	SS 7170 is deleted with Addendum 1.
14	5/3/2022	Special Specification 7184 contains references to SAWS specs (San Antonio Water System) and a City of San Antonio audit. Please confirm this, and any other City of San Antonio references, DO NOT apply to this project.	SS 7184 is deleted with Addendum 1.
15	5/3/2022	Special Specification 7196 contains references to SAWS specs (San Antonio Water System) and a City of San Antonio audit. Please confirm this, and any other City of San Antonio references, DO NOT apply to this project.	SS 7196 is deleted with Addendum 1.
16	5/3/2022	pecial Specification 7234 contains references to the City of Stephenville (CITY) requirements. Please confirm this, and any other City of Stephenville references, DO NOT apply to this project.	SS 7234 is deleted with Addendum 1.
17	5/3/2022	Special Specification 7234 also contains a five-year experience requirement. Please confirm this requirement, DOES NOT apply to this project.	SS 7234 is deleted with Addendum 1.
18	5/3/2022	Special Specification 7243 contains references to the City of Haslet (City) requirements. Please confirm this, and any other City of Haslet (City) references, DO NOT apply to this project.	SS 7243 is deleted with Addendum 1.
19	5/3/2022	Special Specification 7261 contains references to the City of Grandview requirements and policies. Please confirm this, and any other City of Grandview references, DO NOT apply to this project.	SS 7261 is deleted with Addendum 1.
20	5/3/2022	Please provide the as builts for the retaining wall	We are placing retaining wall & standards as-builts in the Documents 4122022"/ retaining wall & Standards subdirectory.
21	5/3/2022	On sheet #213, Water Line B, there is a callout for 74 LF of 20" Steel Casing by Bore. But I don't see a bid item for that. Would you add a bid item?	This work is added with Addendum 1 on sheet 209, item 7294-6027
22	5/3/2022	Who pays for material testing?	Material testing under SS 7294 is at the expense of the contractor per 7294.3.2.
23	5/3/2022	The existing pavement on FM 544 consist of 8" Concrete over 4" of Asphalt. In the removal scope, under which item the removal of the existing asphalt will be paid for? Would you add a bid item for that?	There is a minor plan error. The removal item 0105 6052 REMOVE STAB BASE & ASPH PAV (4"-5"), paid by the SY was intended to be included in the EQ and Summary Sheet. Any change in the plans will be addressed as outlined in the Spec Book under Item 4, "Scope of Work."
24	5/3/2022	Are we required to furnish a maintenance bond (City of Wylie?) for any of this multi-spec water line construction that contains a one-year guarantee?	Per SS 7294.5, there is a requirement to warranty work for two years following acceptance of the project.
25	5/3/2022	Is the SWPPP subsidiary to other bid items and which item? If not, would you add a bid item?	There are not Sw3P measures specific to water line installation, SW3P plans for the project as a whole are included on pages 182-199. If additional measures are identified during waterline reconstruction, they will be addressed at that time.
26	5/3/2022	On bid item 545-6019, the ABSORB-M is listed in the specs but the SLED TL3 from TrafFix is not.	SLED IS SHOWN ON SHEET 55