

CSJ 0197-02-133, CONTRACTOR QUESTIONS

UPDATED: 05/3/2022

NUMBER	QUESTION	ANSWER
1	Are perimeter signs required on this project?	Yes, perimeter signs will be required on this project.
2	Please add the ITS Spec: 000-395.	Since this project is fully ITS project, we don't believe that the requested Spec should be added. SP 000-395 is only for roadway projects or other projects that have ITS work included with "other" non-ITS work. This project has SP 002-007, 000-387, 000-389, 000-390, 000-391 and 000-392, which means that the contractor must be pre-qualified for ITS work to be able to bid on the job.
3	<p><i>"RVSD must be remote accessible and provide communication options including RS232, RS485 and TCP/IP. RVSD communication through RS232 or RS485 must include an internal RS232, RS485 communication port"</i>.</p> <p>We technically can communicate via all required options but do not have an "internal RS232, RS485 port", it would be external to the unit and placed in the cabinet. Is this acceptable in compliance with this Special Specification?</p>	An external RS-232 / RS-485 communication port installed in the CCTV / RVSD pole mount cabinet will be acceptable to meet Section 2.8 of SS 6304.
4	I see your requiring the perimeter barricades. Will you be requiring the lead ends on main lanes and frontage roads with all major intersections signed? Or how would you purpose?	Yes, perimeter signs will be required with lead ends on main lanes, frontage roads, and all major intersections signed.
5		
6		
7		