

**Pre-Bid Question Form**

Project: FY 2021 BPM  
Control: RMC 6351-25-001  
Highway: Varies  
County: Jeff Davis, etc.

NO.	Question	Response
1	Will strength-testing equipment and a cure facility be required as indicated in the general notes for Item 421? This is typically not required for small projects and for concrete repair work.	Because of the small quantity of Item 421 required for this Bridge Preventative Maintenance project it will not require for the strength-testing equipment and a cure facility to be used.
2	Will perimeter barricades be required at each location or can daily lane closure signs and channelizing devices be used?	Barricades & Traffic Control Plan (TCP) are required as deemed necessary by Engineer.