

## 0902-90-103 Pre-Bidding Questions & **Answers**

1. Please provide clarification on the item below, what is being referred to as “6000 6159 INSTALL CONTROL TRANS (HIGH MAST)”

This item is for the installation of the control transformer for high mast lighting. This is the 0.75 KVA transformer used to convert 480V to 120V for obstruction lights. If no obstruction lights are present, the transformer is not used.

2. What part of the hi-mast does this item belong to?

This is located on the ring inside this junction box or is mounted externally to it.

3. Is this project federally or state funded?

State.

4. Is most of this contract to be considered specialty work and if so what percentage?

The work for this contract is non-site specific and will have work called out for in work orders that will be issued. The work will consist of the various bid items included in the contract.

5. Does the prime contractor have to perform a minimum of 30% of the original contract on this project?

Yes.

6. Are the items under pay item 6156-6006 include the ring and lowering assembly or just replacing the fixtures?

No, just the fixtures and other items related to the fixtures as defined in the specification under “luminaire replacement.”