

PROSPECTIVE BIDDER'S INQUIRIES

CSI: 0422-03-084

Bid Opening Date: Wednesday, February 1, 2023

No.	Question	Date Received	Response	Response Date
1	We are preparing our bid for the referenced project and request that you populate the FTP with any and all cross sections, pavement design reports, earthwork files, digital earthwork data (*.XML format, if possible), geotechnical reports, global stability analysis, time calculation data, subsurface utility plans, detour cross sections, ROW Maps, As-Built data, and other files/data you may have available to assist in our preparation of a proposal for this project at your earliest convenience.	1/10/2023	The as-builts have been uploaded to the FTP. Other files as requested were not needed for this type of project.	1/12/2023
2	Item 506 Rock Filter Dams – The Standard Sheet EC (2)-16 Note 4 requires 6:1 side-slopes for dams within the “safety zone”. As the term “safety zone” is never actually defined anywhere we have been able to locate, will 6:1 RFDs be required on this project?	1/10/2023	The "safety zone" is intended to be 30 ft from the edge of travel lane, hence 6:1 RFD is required.	1/12/2023
3	Will a CEI firm be utilized for this project?		The usage of a CEI contract on this project has not been determined.	1/12/2023

Document Revised: Thursday, January 12, 2023

TxDOT Public FTP at the following address:
<ftp.dot.state.tx.us/pub/txdot-info/Pre-Letting%20Responses/>