

April 4, 2022

IH 20, etc. CSJ: 6391-79-001 Parker County, Texas

1. Is it just restripe existing thermo lines?

Yes.

2. What type of beads are aloud?

Meets standard specs and in accordance with DMS-8290.

3. And do the cracks in the stripe will they need to be filled by thermo?

The final thickness must match the bid item.