

US 377 Erath County

RMC: 6360-69-001

July 2020

Q1: General notes refer to removal by milling and requires the use of a paver. However, the general note on sheet 2B of the plans above item 4.4 states that this project consists of Flexible Pavement Structure Repair (Pothole). Just confirming that there is no pothole repair in this project?

A1: We only have flexible pavement structure repair (Item 351) and will be paid in accordance Item 351.

Q2: The general notes and typical sections call for SAC A PG70-28 Type C for the surface of all patches. Is SAC-A really going to be required for flex pavement repair?

A2: Yes

Q3: This project refers to Erath, Hood, & Somervell Counties. Are there any specific areas that you have in mind for this work or will it be as scattered as advertised?

A3: Yes, the work will be done in all three counties as needed.

Q4: Since this project is not site specific will item 500 6033 be paid with each work order as outlined in item 5.12.3 on sheet 2B of the general notes?

A4: Yes, by each (for each work order not by Location)

Q5: The plans state a daily minimum of 455 square yards. Can you tell me what daily production rate was used to arrive at the estimated cost?

A5: We arrive to the estimated cost based on quantities. Contract Time Calculation Sheet to determine days.

