

Date	Question/Request	Response	Response Date
6/23/2021	<p>Will the traffic signal modification work be allowed during daytime hours since it will have minimal impacts to the motoring public and many of the vendors required for the activation will not work at night?</p>	<p>Traffic signal modification work shall be allowed during daytime hours as long as there is minimal impact to the traveling public.</p>	6/23/2021
6/23/2021	<p>The proposal contains item 354-6002 Plan & Text Asph Conc Pav (0" to 2"). This is for milling at the beginning and end of the project and at the Mustang Bayou bridge. Shouldn't this be plan and text conc pav?</p>	<p>Item 354-6002 is intended for Plan & Text Conc Pav (0" to 2") at the beginning/end of project and also at the Mustang Bayou bridge, bid as-is.</p>	6/23/2021