

PREBID QUESTION AND RESPONSE LOG
SH 36 - 0111-08-100

DATE	QUESTION/REQUEST	RESPONSE	RESPONSE DATE
7/12/2021	Will the Roadway Excavation material be able to be used for the TY C Embankment? Can a detail be provided for Item 400-6006 Cut & Restore Pav 137 SY?	Yes, provided it meets all the requirements of the item 132 specification and general notes. See plan sheets 123-124 for details.	7/12/2021