

PREBID QUESTION AND RESPONSE LOG

SH 36 - 0111-08-100

DATE	QUESTION/REQUEST	RESPONSE	RESPONSE DATE
7/14/2021	<p>Sheet 27 has the Summary of MBGF Items. Where are these items called out in the plans?</p> <hr/> <p>Sheet 40 Note #5 under Removal of Median Barrier Notes states "Upon Completion of Phase III 1260' SSCB, CCA, and 30' Barrier Transition will be reinstalled at the same location" Is it your intent to reuse the existing barrier that we removed under item 104-6037 Remove Conc (Rail) 1,290 LF?</p>	<p>The MBGF will be located at the cross structure at station 2036+62.87.</p> <hr/> <p>No it is not the intention to use the existing barrier. The intent is that when the temporary barrier is removed from phase 3 that the permanent barrier (Item 514) will be placed in the same location as the original permanent barrier was. Also see note 4 of sequence of work on page 48 for further clarification.</p>	7/15/2021