

CSJ 0598-02-119
SH 288
Brazoria County

Pre Letting Questions & Answers 3
9/24/2020

Date Question Received	Questions / Answers
9/23/2020	<p>Q. Is the use of fiber reinforced concrete in lieu of rebar/mesh allowed for the 5” riprap in the channel?</p> <p>A. The use of fiber reinforced concrete in lieu of rebar/mesh is not allowed for the 5” riprap in the channel, please proceed as per Specifications.</p>