

### Pre-bid Questions and Answers CSJ # 0027-12-158

8/26/2022	The construction schedule that was provided shows a Phase 3, where we construct the permanent median barrier. The traffic control plan in the plans only shows 2 phases, not the third where we install the permanent barrier. Please advise.	Acknowledged. Bid per plan.
8/26/2022	Will the new rail, permanent barrier, and bridge require painting?	Yes. Painting will be required to match adjacent roadway sections on both sides.
8/26/2022	Is there any lead or contaminated material in the existing bridge that we demo?	Report has been posted to the FTP site.
8/26/2022	Are the rail quantities correct? Bridge Layout on sheet 96 shows 504 LF to be T-551, not SSTR.	Acknowledged. Bid per plan.