

**CSJ 0367-02-082  
SH 87  
Galveston County**

**Pre-Letting Questions & Answers 1  
8/11/2022**

<b>Date Question Received</b>	<b>Questions / Answers</b>
8/9/2022	<p>Q. On plan sheet #49, Coastal Protection Roadway Revetment Typical Detail, it calls for a one-foot-thick bedding stone. Per the standard specification 432 under section 5 Payment, the bedding stone will be made for under the item "BEDDING MATERIAL". There is no pay item for this work. How will it be paid for?</p> <p>A. The bedding stone will be paid under 432-6031 RIPRAP (STONE PROTECTION) (12 IN).</p>
8/9/2022	<p>Q. On plan sheet #5 Estimate &amp; Quantity Sheet there is a bid item 423-6031 RIPRAP (STONE PROTECTION)(12 IN). Where is this item used on the project. There is no call out for this type or Riprap on the plans. Where will this item be used?</p> <p>A. Bid item 432-6031 pays for 12" bedding stone shown on sheet #49.</p>
8/9/2022	<p>Q. On plan sheet #4B, General Notes, the note under Item 432 Riprap states to use common riprap if stone riprap is shown on the plans. Shouldn't this note be deleted because the job is stone protection?</p> <p>A. Common riprap should be used as per General Notes. Refer to sheet 49, note 7, "use of crushed concrete is not approved".</p>
8/10/2022	<p>Q. Can you provide the cross sections for the Galveston Co. SH 87 CSJ 0367-02-082 project? Can the end areas be included on the cross sections for each station/cross section??</p> <p>A. At this time, cross sections were not generated for the project.</p>