

## Pre-Letting Response(s)

Project Number: RMC: 6327-41-001

Date Last Updated: April 2, 2019

Date Question Received	Question	Response
04/02/19	<p>Mr. Leong,</p> <p>After more investigation we have found that the existing wall was an experimental project that used 3 different suppliers using 3 different patented sound absorbing materials. We have contacted 2 of the suppliers and they no longer have agreements with the company and are not interested since there are only 3 panels to replace.</p> <p>With this n mind we would recommend a standard pre cast concrete panels to replace the existing with the same form liner and paint to match.</p>	<p><b>The sound wall panels to be replaced on this contract may be standard pre-cast concrete panels matching the existing form liner and paint color as the existing wall panels.</b></p>