

BPM 6335-20-001

Pre-Bid Questions and Answers

1. On Bid Item Code 0545-6001, can the SLED be bid as an alternative for this project?
  - a. We will accept any approved Crash Cushion that meets the intended purpose. We only placed two standards in the plan set to avoid the proprietary product issue. The contractor may utilize any approved device that is equal to those on the standard sheets in the plan set.
2. A few items on the project seem to show different quantities between the E&Q summary and the quantity sheets for each location. For instance, Item 432 (RR8&RR9) and 429 (Rapid V&OH). Which quantity is the correct one?
  - a. Item 432-6045 RipRap (Conc)(Cl B)(RR8&RR9) the correct quantity should be 97CY. This matches the total from the summary sheets. Items 429-6008 (2550 SF) and 432-6008 (212 CY), quantities shown on the E&Q sheet are correct.