

PROSPECTIVE BIDDER'S INQUIRIES

RMC: 6351-18-001 (Trinity County) Ditch & Culvert Cleaning			
Bid Opening Date: 12/11/2019			
No.	QUESTION	TxDOT MNT OFFICE RECEIVED QUESTION FROM BIDDER	RESPONSE
		DATE	
1	What size/will there be box culverts to be cleaned on this contract?	11/25/2019	Sheet 4 of the plans (QUANTITY SUMMARIES) shows that Item 480 "Clean Existing Culverts" is intended for cleaning driveway pipes.
2	What is the minimum size crew needed for the ditch cleaning portion of this contract?	11/25/2019	See general notes under Item 8: Prosecution and Progress.
3	Will there be locations that need the use of the hydraulic excavator?	11/25/2019	Yes.
4	Is this a 24" standard pipe size?	11/22/2019	The Lufkin District typically uses 18" Reinforce Concrete Pipe on new installations, but land owners place corrugated metal pipe frequently. The size ranges from approximately 12" to larger.
5	Are the seeding and temporary sediment control fence quantities estimates?	11/25/2019	Yes. As shown on Sheet 4, "Use as directed".