

## Project Q & A's 10/26/2020

Letting: November 5, 2020

Project: RMC 637022001

CCSJ # 6370-22-001

Highway: IH20

County: Ector

1. For Item 438-6001 Cleaning and Sealing existing joints-no details or notes in the plans telling us what material we are supposed to use for this work?

Answer: Provide Class 7 silicone sealant in accordance with DMS-6310, "Joint Sealants and Fillers" for joints in concrete. Extend sealant up into rail or curb 3 inches on low side or sides of deck. If the class 7 sealant cannot be effectively placed in the vertical position, a class 4 sealant compatible with the Class 7 sealant is allowed for the extension of the seal into the curb or rail. Prepare surfaces where sealant is to be placed in accordance with the manufacturer's specifications. Obtain approval for all tools, equipment, materials and techniques proposed for use to prepare the joint.

2. Item 429 Rapid Deck Full Depth Repair-since this is item 429 are we allowed to use either ready mix or TXDOT approved bagged material for this repair?

Answer: Ready mix or TXDOT approved bagged material will be allowed.