

Project Q & A's 10/26/2020

Letting: November 5, 2020

Project: RMC 637022001

CCSJ # 6370-22-001

Highway: IH20

County: Ector

1. The Joint Repair Detail for Item 429-6006 allows for class S and class K concrete. I am assuming this means that overnight lane closures are approved to allow proper curing time in order to reach 3,600 psi. Is this correct? **Answer: Yes overnight lane closures will be approved.**