

TxDOT San Angelo District
Contractor Questions and Responses

CSJ 6422-14-001
let date 10/7/2022

QUESTION NUMBER	CONTRACTOR QUESTION	TxDOT RESPONSE
1	Sheet 18 Note 6 has start date of October 3 rd & complete by February 28, 2023 – job doesn't bid until 10-7-22 – would assume that we would have 180 working days from notice to proceed to complete the project?	The October 3 rd & complete by February 28, 2023 reference is to the non-nesting season of any migratory birds. Work must be completed within this time frame or special permission will have to be obtained.
2	Does TXDOT have a sequence of the order of the sites to be completed or is the sequence left to the contractor?	Sequence is the contractor's option.
3	Sheet 53 – lead sheet details – are the lead sheet dimensions the same both structures – B10 & H5?	Yes
4	Sheet 54 – bearing pad detail for site H10 – summary table is blank & bearing pads have no dimensions & note 2 has no KIPS listed– need to know the size of bearing pads & estimated weight of the structure	Bid as advertised.
5	Site D2 – has Item 446-6028 – Spot Clean & Paint Exist Str (SPL PRT SYS) - 3 LS – is this supposed to be 3 each?	This item is paid per location, so 3 each.
6	Sheet 11 – D2 - Note says to clean & paint exposed steel piles at east abutment – is there an estimates SF to be painted?	There is not a SF indicated. Recommend a site visit.
7	Sheet 11 – D2 – did not see anything that tells us the Type of paint that you want installed	Paint is specified in Item 446 in the Standard Specifications for Construction and Maintenance of Highways, Streets and Bridges.