

PROSPECTIVE BIDDER'S INQUIRIES

CSJ: 6309-18-001

Bid Opening Date: 8/21/2019

No.	Question	Date Received	Response	Response Date
1	What is the purpose for the Rock Filter Dams?	8/14/2019	Use of the RFD's will be as determined once construction begins. They are not for use in the river itself, but may be used if a need presents itself once work has begun as determined by the engineer.	8/14/2019
2	Where are sources for concrete.	8/14/2019	Uvalde Concrete in Uvalde and Chism Concrete in Leakey are the two closest suppliers.	8/14/2019
3	Is there a place that the removed concrete can be disposed of?	8/14/2019	Some of the materials may be used as fill material under the proposed riprap (as shown in the plans). Could try contacting adjacent property owners to see if they could use the material.	8/14/2019
4	Do we want vegetation removed as part of the Prep ROW item?	8/14/2019	Yes, we want to clean up some undesirable vegetation in addition to the removal of debris, old rebar and fill material under this item.	8/14/2019
5	How much material has to be removed in areas where old concrete is to be removed?	8/14/2019	All existing concrete and existing fill material above the natural river bed is to be removed.	8/14/2019

Document Revised on: 8/14/2019

TxDOT Public FTP at the Following Address:

<https://ftp.dot.state.tx.us/pub/txdot-info/Pre-Letting%20Responses/>