

PROSPECTIVE BIDDER'S INQUIRIES

CSJ: 6376-06-001

Bid Opening Date: 3/17/2021

No.	Question	Date Received	Response	Response Date
1	Will the bushes need to be removed?	3/15/2021	If the bushes are within the footprint of the mow strip or proposed riprap work area, then they will need to be removed. This work will be paid for as Prep ROW.	3/16/2021
2	Is the 290 CY of flowable fill accurate?	3/15/2021	This quantity is an estimated amount based on historic data from similar type of erosion at various locations. The exact amount may vary from this amount.	3/16/2021
3	Can cement stabilized sand be used in lieu of flowable fill?	3/15/2021	Alternative equivalent material may be proposed by the successful bidder provided that the proposed material fulfills the proposed line and grade as is required in the plans and in the field. Acceptance of this change in material will be determined by the Engineer.	3/16/2021

Document Revised on: 3/16/2021

TxDOT Public FTP at the Following Address:

<https://ftp.dot.state.tx.us/pub/txdot-info/Pre-Letting Responses/>