

PROSPECTIVE BIDDER'S INQUIRIES

CSJ: 6387-72-001

Bid Opening Date: 5/5/2022

No.	Question	Date Received	Response	Response Date
1	The T2 rail, when originally installed 3/4" button head bolts were used to attach the rail to the post. 3/4" button head bolts are unavailable, obsolete and no longer manufactured. Can we use a 3/4" carriage bolt instead?	4/25/2022	Carriage bolts will be a suitable substitute for the button head bolts.	4/25/2022
2	If allowed to use 3/4" carriage bolt. Will we be allowed to torch cut square holes in the new C-12 x 20.7 rail?	4/25/2022	Using a cutting torch to create the required square hole in the field will be acceptable. However, the Contractor will need to take care as not to make the holes in the rail bigger than the size of the carriage bolt being installed. The slag from cutting these holes will need to be ground down smooth after the holes are established.	4/25/2022

Document Revised on: 4/25/2022

TxDOT Public FTP at the Following Address:

<https://ftp.dot.state.tx.us/pub/txdot-info/Pre-Letting Responses/>