

## PROSPECTIVE BIDDER'S INQUIRIES

CSJ: 6339-32-001

Bid Opening Date: 10/02/2019

No.	Question	Date Received	Response	Response Date
1	After all removal of the pipe is completed and the boxes are installed, how is the contractor supposed to fill the voided space from edge of cement stabilized backfill around the boxes to the extent that was needed to remove the pipe?	9/16/2019	Note #4 on Sheet 32 of the plan set says to "Place cement stabilized backfill in void where existing culvert is removed." This volume was recalculated to check the quantity and appears to take the area in question into account. For clarity, the intent of the "Cement Stabilized Backfill Detail" on sheet 33 of the plan set is to note that the limit of excavation for installing the box culverts where no additional excavation is required is 1 ft beyond the dimension of the box culverts being installed (for example, below the flowline of the existing pipe culverts). This detail does not take into account the existing pipe culverts that need to be removed. The contractor shall take precautions not to excavate any excess material than is required to remove the existing culverts and install the new box culverts and minimize the volume of cement stabilized backfill required to complete the installation.	9/16/2019
2	In the general notes on sheet 5, under section 4 it states, "This project includes plan sheets that are not part of the bid proposal." Can you please clarify what these plan sheets are for and where they are available?	9/23/2019	This note is to inform the Contractor that there are signed and sealed plan sheets that are available that are not part of the Bid Proposal packet. This would be the signed and sealed 11x17 plans that the project is constructed from. These plan sheets are not included in the Bid Proposal packet and they must be obtained by the Contractor. These plan sheets are available via the TxDOT Plans Online system that can be found at <a href="http://www.txdot.gov">www.txdot.gov</a> .	9/25/2019

# PROSPECTIVE BIDDER'S INQUIRIES

CSJ: 6339-32-001

Bid Opening Date: 10/02/2019

Document Revised on: 09/25/2019

TxDOT Public FTP at the Following Address:

<https://ftp.dot.state.tx.us/pub/txdot-info/Pre-Letting%20Responses/>