

PROSPECTIVE BIDDER'S INQUIRIES

CSJ: 6347-34-001

Bid Opening Date: 10/03/2019

No.	Question	Date Received	Response	Response Date
1	No seal shown on Sect #3 , is this tack only	10/2/2019	This is correct. There is no seal coat required for the full depth pavement repair areas. Only tack coat as described below the typical section.	10/3/2019
2	Is call out for mob paid for each call out or only for non-site specific locations (sht 4 note)	10/2/2019	A callout mobilization will be paid for each callout work order that is issued. This includes both site specific and non-site specific work locations.	10/3/2019
3	Shts 48 & 49 does the note that specific locations may not be located w/in locations listed mean the specific locations may or may not be done ?	10/2/2019	The limits of the site specific locations shown in the plans provide a general location of the work to be performed. The intent is to select locations within the limits shown for pavement repairs. However, the actual locations selected may fall outside of the limits shown, but should be within a reasonable distance from the limits shown.	10/3/2019
4	Do wk zn non rem mrk have to be placed each day ? No temp tabs are set up.	10/2/2019	Yes, the Sequence of Work Narrative sheet 6 directs that Contractor to place non removable work zone pavement markings prior to opening lanes to traffic. Therefore, no temporary tabs are set up for the contract.	10/3/2019

Document Revised on: 10/3/2019

TxDOT Public FTP at the Following Address:

<https://ftp.dot.state.tx.us/pub/txdot-info/Pre-Letting%20Responses/>