

# PRE-LETTING QUESTIONS AND ANSWERS

CONTROL: 6367-18-001 COUNTY: Wilbarger AREA OFFICE: Wichita Falls HIGHWAY: US 283  
 PROJECT: RMC 6367-18-001 LET DATE: 2/4/2021 AREA ENGINEER: Callan Coltharp, P.E. EMAIL QUESTIONS TO: [callan.coltharp@txdot.gov](mailto:callan.coltharp@txdot.gov)

**\*\*CHANGES FROM PREVIOUS VERSION HAVE BEEN HIGHLIGHTED BELOW\*\***

PREVIOUS VERSION: N/A CURRENT VERSION: 1

#	DATE RECEIVED	STATUS	QUESTION	ANSWER
1	1/28/2021	In Progress	Is there a maximum milling depth for each pass in the HIR operation?	Yes, milling depth shall be limited to <u>1/2 inch</u> per pass, unless the contractor is able to demonstrate a different process that sufficiently heats the existing material and does not damage the existing aggregate.
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				